

## Facility Information Detail (FIND)

[Search Again](#) | [Search Results](#) | **[Facility Details](#)** | [Equipment List](#) | [Compliance](#) | [Emissions](#) | [Hearing Board](#) | [Transportation](#)

### Facility Details

**Facility ID** 138823  
**Company Name** MAERSK DISTRIBUTION SERVICES INC  
**Address** 5011 FIRESTONE PL  
SOUTH GATE, CA 90280

[View Area Map](#)

**Status** ACTIVE

**Are there any back fees due?**

No.

[Home](#) | [Employment](#) | [Contact Us](#) | [Terms & Conditions](#) | [Privacy](#) | [Website Navigation Tips](#) | [Question or Need Info?](#) | [Report Website Problem](#)  
21865 Copley Dr, Diamond Bar, CA 91765 - (909) 396-2000 - (800) CUT-SMOG (288-7664)

## Facility Information Detail (FIND)

[Search Again](#) | [Search Results](#) | [Facility Details](#) | [Equipment List](#) | [Compliance](#) | [Emissions](#) | [Hearing Board](#) | [Transportation](#)

### Equipment List

**Facility ID** 138823  
**Company Name** MAERSK DISTRIBUTION SERVICES INC  
**Address** 5011 FIRESTONE PL  
 SOUTH GATE, CA 90280

Appl_Nbr	Permit_Nbr	Issued_Date	Permit_Status	Eq_Type	Equip_Description	Appl_Date	Appl_Status
426851	F76105	6/16/2005	ACTIVE	Basic	I C E (50-500 HP) EM ELEC GEN-DIESEL	3/9/2004	PERMIT TO OPERATE GRANTED

Page 1 of 1 (1 records)

Page 1

[Home](#) | [Employment](#) | [Contact Us](#) | [Terms & Conditions](#) | [Privacy](#) | [Website Navigation Tips](#) | [Question or Need Info?](#) | [Report Website Problem](#)  
 21865 Copley Dr, Diamond Bar, CA 91765 - (909) 396-2000 - (800) CUT-SMOG (288-7664)

## Facility Information Detail (FIND)

[Search Again](#) | [Search Results](#) | [Facility Details](#) | [Equipment List](#) | [Compliance](#) | [Emissions](#) | [Hearing Board](#)

### Application Details

Application/Tracking Number 426851

### Facility Information

Business Name MAERSK DISTRIBUTION SERVICES INC

Facility ID	138823	Facility Status	ACTIVE
-------------	--------	-----------------	--------

### Application Information

Application Type	Permit to Operate without prior Permit to Construct	Application Received	3/9/2004
------------------	---	----------------------	----------

Application Status	PERMIT TO OPERATE GRANTED	Application Deemed Complete	4/2/2004
--------------------	---------------------------	-----------------------------	----------

Equipment Desc I C E (50-500 HP) EM ELEC GEN-DIESEL

Permit Number	F76105	Permit Status	ACTIVE
---------------	--------	---------------	--------

[View Permit Image](#)

### Engineer Information

Engineer Assigned ROY OLIVARES JR

Engineer Phone	(909) 396-2208	Team Assigned	J
----------------	----------------	---------------	---

[Home](#) | [Employment](#) | [Contact Us](#) | [Terms & Conditions](#) | [Privacy](#) | [Website Navigation Tips](#) | [Question or Need Info?](#) | [Report Website Problem](#)  
 21865 Copley Dr, Diamond Bar, CA 91765 - (909) 396-2000 - (800) CUT-SMOG (288-7664)



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21885 East Copley Drive, Diamond Bar, CA 91765

## PERMIT TO OPERATE

Page 1  
Permit No.  
076105  
APN 426851

This initial permit must be renewed **ANNUALLY** unless the equipment is moved, or changes ownership.  
If the billing for the annual renewal fee (Rule 301.5) is not received by the expiration date, contact the District.

Legal Owner  
or Operator:

HUDD DIST SERVICES INC  
5011 FIRESTONE PL  
SOUTH GATE, CA 90280-3533

ID 138823

Equipment Location: 5011 FIRESTONE PL, SOUTH GATE, CA 90280-3533

### Equipment Description :

INTERNAL COMBUSTION ENGINE, PERKINS, MODEL 1006-6T, DIESEL FUELED, TURBOCHARGED,  
RATED AT 151 B.H.P, DRIVING AN EMERGENCY STAND-BY GENERATOR

### Conditions :

1. OPERATION OF THIS EQUIPMENT SHALL BE CONDUCTED IN ACCORDANCE WITH ALL DATA AND SPECIFICATIONS SUBMITTED WITH THE APPLICATION UNDER WHICH THIS PERMIT IS ISSUED UNLESS OTHERWISE NOTED BELOW.
2. THIS EQUIPMENT SHALL BE PROPERLY MAINTAINED AND KEPT IN GOOD OPERATING CONDITION AT ALL TIMES.
3. THE OPERATOR SHALL NOT PURCHASE ANY DIESEL FUEL UNLESS THE FUEL IS LOW SULFUR DIESEL FOR WHICH THE SULFUR CONTENT DOES NOT EXCEED 15 PPM BY WEIGHT. AS OF JANUARY 1, 2006, THE OPERATOR SHALL ONLY USE DIESEL FUEL WITH A SULFUR CONTENT THAT DOES NOT EXCEED 15 PPM BY WEIGHT, UNLESS THE OPERATOR DEMONSTRATES IN WRITING TO THE EXECUTIVE OFFICER THAT SPECIFIC ADDITIONAL TIME IS NECESSARY.
4. AN OPERATIONAL NON-RESETTABLE TOTALIZING TIME METER SHALL BE INSTALLED AND MAINTAINED TO INDICATE THE ENGINE ELAPSED OPERATING TIME.
5. THIS ENGINE SHALL BE OPERATED TO A MAXIMUM OF 200 HOURS PER CALENDAR YEAR WHICH INCLUDES A MAXIMUM OF 20 HOURS PER YEAR FOR REGULAR MAINTENANCE AND TESTING
6. THE ENGINE TIMING SHALL BE RETARDED 4 DEGREES RELATIVE TO STANDARD ENGINE TIMING
7. ON OR AFTER JANUARY 1, 2006 THE ANNUAL HOURS OF OPERATION FOR MAINTENANCE AND TESTING SHALL BE NO MORE THAN 20 HOURS PER YEAR AS REQUIRED IN RULE 147(C)(3).

FILE COPY



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 East Copley Drive, Diamond Bar, CA 91765

**PERMIT TO OPERATE**

Page 2  
Permit No.  
F76105  
A/N 426851

CONTINUATION OF PERMIT TO OPERATE

8. OPERATION BEYOND THE ALLOTTED TIME FOR ENGINE MAINTENANCE AND TESTING SHALL BE ALLOWED ONLY IN THE EVENT OF A LOSS OF GRID POWER OR UP TO 30 MINUTES PRIOR TO A ROTATING OUTAGE, PROVIDED THAT THE UTILITY DISTRIBUTION COMPANY HAS ORDERED ROTATING OUTAGES IN THE CONTROL AREA WHERE THE ENGINE IS LOCATED OR HAS INDICATED THAT IT EXPECTS TO ISSUE SUCH AN ORDER AT A CERTAIN TIME, AND THE ENGINE IS LOCATED IN A UTILITY SERVICE BLOCK THAT IS SUBJECT TO THE ROTATING OUTAGE. ENGINE OPERATION SHALL BE TERMINATED IMMEDIATELY AFTER THE UTILITY DISTRIBUTION COMPANY ADVISES THAT A ROTATING OUTAGE IS NO LONGER IMMINENT OR IN EFFECT.
9. THIS ENGINE SHALL NOT BE USED AS PART OF A DEMAND RESPONSE PROGRAM USING INTERRUPTIBLE SERVICE CONTRACT IN WHICH A FACILITY RECEIVES A PAYMENT OR REDUCED RATES IN RETURN FOR REDUCING ITS ELECTRIC LOAD ON THE GRID WHEN REQUESTED TO DO SO BY THE UTILITY OR THE GRID OPERATOR.
10. THIS EQUIPMENT SHALL COMPLY WITH RULE 1470.
11. AN ENGINE OPERATING LOG SHALL BE KEPT AND MAINTAINED ON FILE TO RECORD WHEN THIS ENGINE IS STARTED MANUALLY. THE LOG SHALL LIST THE DATE OF OPERATION, THE TIMER READING IN HOURS AT THE BEGINNING AND END OF OPERATION, AND THE REASON FOR OPERATION FOR A MINIMUM OF THIRTY SIX MONTHS PRIOR TO THE CURRENT YEAR AND MADE AVAILABLE TO DISTRICT PERSONNEL UPON REQUEST. THE TOTAL HOURS OF OPERATION (INCLUDE HOURS FOR MANUAL AND AUTOMATIC OPERATION) SHALL BE RECORDED SOMETIME DURING THE FIRST 15 DAYS OF JANUARY OF EACH YEAR.

**FILE COPY**



SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT  
21865 East Copley Drive, Diamond Bar, CA 91765

**PERMIT TO OPERATE**

Page 3  
Permit No.  
F76185  
A/N 426881

---

CONTINUATION OF PERMIT TO OPERATE

---

**NOTICE**

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR COPY SHALL BE POSTED ON OR WITHIN 8 METERS OF THE EQUIPMENT.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT CANNOT BE CONSIDERED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF OTHER GOVERNMENT AGENCIES.

EXECUTIVE OFFICER

A handwritten signature in cursive script, reading "Dennis M. Bailey", is positioned above the typed name.

By Dennis M. Bailey/RO01  
6/16/2005

**FILE COPY**



## Facility Information Detail (FIND)

[Search Again](#) | [Search Results](#) | [Facility Details](#) | [Equipment List](#) | [Compliance](#) | [Emissions](#) | [Hearing Board](#) | [Transportation](#)

### Compliance

**Facility ID** 138823  
**Company Name** MAERSK DISTRIBUTION SERVICES INC  
**Address** 5011 FIRESTONE PL  
 SOUTH GATE, CA 90280

### Notices Of Violation

<u>Notice Number</u>	<u>Notice Issue Date</u>	<u>Violation Date</u>	<u>Disposition Date</u>	<u>Disposition</u>
P42320	12/18/2003	12/11/2003	5/13/2004	Closed Case

[First](#)
[Prev](#)
Page 1 of 1 (1 records)
 [Next](#)
[Last](#)
Page 
[Export To Excel](#)


### Notices To Comply

<u>Notice Number</u>	<u>Violation Date</u>	<u>Re-Inspection Date</u>	<u>Status</u>
C87573	12/11/2003	12/18/2003	In Compliance
D16739	8/12/2008	8/20/2008	In Compliance

[First](#)
[Prev](#)
Page 1 of 1 (2 records)
 [Next](#)
[Last](#)
Page 
[Export To Excel](#)

---

[Home](#) | [Employment](#) | [Contact Us](#) | [Terms & Conditions](#) | [Privacy](#) | [Website Navigation Tips](#) | [Question or Need Info?](#) | [Report Website Problem](#)  
 21865 Copley Dr, Diamond Bar, CA 91765 - (909) 396-2000 - (800) CUT-SMOG (288-7664)



## Facility Information Detail (FIND)

[Search Again](#) | [Search Results](#) | [Facility Details](#) | [Equipment List](#) | [Compliance](#) | [Emissions](#) | [Hearing Board](#) | [Transportation](#)

### NOV/NC Details

Notice Number	P42320	Violation Date	12/11/2003	Issue Date	5/13/2004	Notice Type	NOV
---------------	--------	----------------	------------	------------	-----------	-------------	-----


Facility ID	138823
Company Name	HUDD DIST SERVICES INC
Address	5011 FIRESTONE SOUTH GATE, CA 90280
Violation Description	INSTALLING/OPERATING AN INTERNAL COMBUSTION ENGINE 9ICE) PERKINS SERIAL #YB50604U708557D, DIESEL - FIRED RATED 151 BHP WITHOUT PERMIT FROM THE AQMD.
Equipment Description	
Follow Up Status	In Compliance
Disposition	Closed Case
Disposition Date	5/13/2004

<b>Rule No.</b>	<b>Rule Description</b>
201	Permit To Construct
203	Permit to Operate

---

[Home](#) | [Employment](#) | [Contact Us](#) | [Terms & Conditions](#) | [Privacy](#) | [Website Navigation Tips](#) | [Question or Need Info?](#) | [Report Website Problem](#)  
 21865 Copley Dr, Diamond Bar, CA 91765 - (909) 396-2000 - (800) CUT-SMOG (288-7664)





## Facility Information Detail (FIND)

[Search Again](#) | [Search Results](#) | [Facility Details](#) | [Equipment List](#) | [Compliance](#) | [Emissions](#) | [Hearing Board](#) | [Transportation](#)

### NOV/NC Details


Notice Number	C87573	Violation Date	12/11/2003	Issue Date	12/31/9999	Notice Type	NC
---------------	--------	----------------	------------	------------	------------	-------------	----

Facility ID	138823
Company Name	HUDD DIST SERVICES INC
Address	5011 FIRESTONE SOUTH GATE, CA 90280
Violation Description	PROVIDE INFORMATION REGARDING THE BHP FOR THE PERKINS EMERGENCY ICE SERIAL #YB50604U7085579
Equipment Description	
Status	In Compliance
Re-inspection Date	12/18/2003

Rule No.	Rule Description
42303	Supply Information, Plans, Specs, Etc.

---

[Home](#) | [Employment](#) | [Contact Us](#) | [Terms & Conditions](#) | [Privacy](#) | [Website Navigation Tips](#) | [Question or Need Info?](#) | [Report Website Problem](#)  
 21865 Copley Dr, Diamond Bar, CA 91765 - (909) 396-2000 - (800) CUT-SMOG (288-7664)



## Facility Information Detail (FIND)

[Search Again](#) | [Search Results](#) | [Facility Details](#) | [Equipment List](#) | [Compliance](#) | [Emissions](#) | [Hearing Board](#) | [Transportation](#)

### NOV/NC Details

Notice Number	D16739	Violation Date	8/12/2008	Issue Date	12/31/9999	Notice Type	NC
---------------	--------	----------------	-----------	------------	------------	-------------	----

Facility ID 138823

Company Name HUDD DIST SERVICES INC

Address 5011 FIRESTONE  
SOUTH GATE, CA 90280

Violation Description update/change business name; provide maintenance/operating log for 2008 to  
verify compliance with P/C

Equipment Description

Status In Compliance

Re-inspection Date 8/20/2008

**Rule No.**

**Rule Description**

---

[Home](#) | [Employment](#) | [Contact Us](#) | [Terms & Conditions](#) | [Privacy](#) | [Website Navigation Tips](#) | [Question or Need Info?](#) | [Report Website Problem](#)  
21865 Copley Dr, Diamond Bar, CA 91765 - (909) 396-2000 - (800) CUT-SMOG (288-7664)